

COMPRESSOR DATA SHEET

In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors Rotary Compressor: Variable Displacement

	M	ODEL DATA - FO	OR COMPRESSED AI	ĪR.		
1	Manufacturer: Quincy Compre	essor .				
2	Model Number: QGDV-2		/ater-cooled	Date: Type:	1/20/2021 Screw	
	X Lubricated Oi		il Free	# of Stages:	1 .	
3*	Full Load Operating Pressure b	125		ps	$psig^b$	
4*	Drive Motor Nominal Rating		25	1	hp	
5	Drive Motor Nominal Efficiency	7	91.00	per	percent	
6	Fan Motor Nominal Rating (if a	n Motor Nominal Rating (if applicable)		. 1	hp	
7	Fan Motor Nominal Efficiency	otor Nominal Efficiency		per	percent	
8	Input Power (kW)		Capacity (acfm)		Specific Power (kW/100 acfm)	
	25.7		117.6	21.	87	
	21.4		100.2	21.:	37	
	18.5		84.1	22.0	01	
	12.6		53.4	53.4 23.62		
	9.8		35.2	27.	27.88	
9*	Total Package Input Power at Zero Flow ^e		0	kWe		
10	Isentropic Efficiency at Full Flow Rated Capacity and Full Load Operating Pressure		66.00	%		
11	35.00 (W) 30.00 V	Note: Y-Axis Scale, 10 to	60.0 80.0 Capacity (ACFM) y a visual representation of the d 35, + 5 kW/100 acfm increments cale, 0 to 25% over maximum cap	if necessary above 35	120.0	

 $Consult\ CAGI\ website\ for\ a\ list\ of\ participants\ in\ the\ third\ party\ verification\ program: \\ \underline{WWW.cagi.org}$

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- d. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m3 / min Below 0.5 0.5 to 1.5 1.5 to 15 Above 15	ft3 / min Below 17.6 17.6 to 53 53 to 529.7 Above 529.7	% +/- 7 +/- 6 +/- 5 +/- 4	% +/- 8 +/-7 +/-6 +/-5	% +/-10%

ROT 032.1

6/20 Rev 2 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

^{*}For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator.