)	COMPRESSOR DATA SHEET Rotary Compressor: Variable Spee	e d Date:	November 9, 2018
A	Manufacturer:	Quincy Compressor		
В	Base Model:	QGDV-30		
С	Cooling:	Air-Cooled		
D	Туре:	Oil-Injected Screw		
E	Stages:	1		
F	Drive Motor Nominal Rating		30	hp
η _{isen}	Full-load package Isent at Rated Capacity and	tropic Efficiency Full Load Operating Pressure ^e	65.0	Percent
G	Rated Capacity at Full Load Operating Pressure ^a		124.8	acfm ^a
н	Full Load Operating Pressure ^b		150	psig ^b
I	Maximum Full Flow Operating Pressure		150	psig ^c
J	Pressure Ratio ^f		11.3	
К	Total Package Input Pc Operating Pressure ^d	ower at Rated Capacity and Full Load	29.9	kW ^d
	Specific Package Input Operating Pressure	Power at Rated Capacity and Full Load	23.96	kW/100 cfm
		ls according to the U.S. Department of Energy (DOE) En the Federal Register for additional information		Standards for Air Compresso federalregister.gov
NOTES: Member	 NOTES: a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E ACFM is actual cubic feet per minute at inlet conditions. b. The operating pressure at which the Capacity (Item G) and Electrical Consumption (Item K) were measured for this data sheet. 			



- for this data sheet.c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the
- maximum pressure attainable before capacity control begins.d. Total package input power at other than reported operating points will vary with control strategy.
- e. Isentropic Efficiency = theoretical power required divided by real measurement performance at same flow and pressure
- **For Variable Speed, this value combines 3 Measured Points: (25% x 40%LOAD) + (50% x 70%LOAD) + (25% x 100%LOAD)
 f. Pressure Ratio = the ratio of discharge pressure to inlet pressure, as determined at full-load operating pressure
 For more information go to: https://www.quincycompressor.com/resources/data-sheets/

This form was developed by Quincy Compressor to publish equipment performance data in accordance with applicable energy conservation standards adopted under EPCA (42 U.S.C. 6295(s) and 6316(a))