	a o	COMPRESSOR DATA SHEET Rotary Compressor: Fixed Spee	ed Date:	November 9, 2018
А	Manufacturer:	Quincy Compressor		
В	Base Model:	QGS-40C		
С	Cooling:	Air-Cooled		
D	Туре:	Oil-Injected Screw		
E	Stages:	1		
F	Drive Motor Nomina	al Rating	40	hp
η_{isen}	Full-load package Ise at Rated Capacity ar	entropic Efficiency nd Full Load Operating Pressure ^e	69.3	Percent ^e
G	Rated Capacity at Full Load Operating Pressure ^a		176.1	acfm ^a
Н	Full Load Operating Pressure ^b		125	psig ^b
I	Maximum Full Flow Operating Pressure ^c		132	psig ^c
J	Pressure Ratio ^f		9.6	
К	Total Package Input Power at Rated Capacity and Full Load Operating Pressure ^d		38.2	kW ^d
	Specific Package Inp Operating Pressure	ut Power at Rated Capacity and Full Load	21.70	kW/100 cfm
-	-	dels according to the U.S. Department of Energy (DOE)) in the Federal Register for additional information		Standards for Air Compresso iederalregister.gov
Member CAGG ompressed Air & Gas Instit	ACFM is actual b. The operating for this data sh c. Maximum pres maximum pres d. Total package i	ne discharge terminal point of the compressor package i cubic feet per minute at inlet conditions. pressure at which the Capacity (Item G) and Electrical Co eet. sure attainable at full flow, usually the unload pressure sure attainable before capacity control begins. nput power at other than reported operating points wil iency = theoretical power required divided by real meas	onsumption (Item K) v setting for load/no lo Il vary with control str	were measured ad control or the ategy.

e. Isentropic Efficiency = theoretical power required divided by real measurement performance at same flow and pressure **For Variable Speed, this value combines 3 Measured Points: (25% x 40%LOAD) + (50% x 70%LOAD) + (25% x 100%LOAD)

f. Pressure Ratio = the ratio of discharge pressure to inlet pressure, as determined at full-load operating pressure For more information go to: https://www.quincycompressor.com/resources/data-sheets/

This form was developed by Quincy Compressor to publish equipment performance data in accordance with applicable energy conservation standards adopted under EPCA (42 U.S.C. 6295(s) and 6316(a))