	MODEL DATA -	FOR CO	MPRESSED AIR		
1	Manufacturer: Quincy Con	npressor			
	Model Number: QGV-75		Date:	Aug-11	
2	Air-cooled X Water-cooled		Type:	Screw	
	X Oil-injected Oil-free	e	# of Stages:	1	
3	Rated Operating Pressure		150	psig ^b	
4	Drive Motor Nominal Rating		75	hp	
5	Drive Motor Nominal Efficiency		95.7	percent	
6	Fan Motor Nominal Rating (if applic	cable)	3	hp	
7	Fan Motor Nominal Efficiency		78.5	percent	
	Input Power (kW)		Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d	
	70.4	Max	295.0	23.86	
	55.7		229.1	24.31	
8*	39.4		146.4	26.91	
	24.8		63.8	38.87	
		Min		#DIV/0!	
9*	Total Package Input Power at Zero F		kW		
	35.00	\backslash			
	30.00				
	÷ŝ				
	25.00 Construction of the second seco				
	20.00				
10	20.00				
	15.00				
	10.00	100.0 105.0 1	50.0 175.0 200.0 205.0 250.0	275.0.200.0.225.0	
	0.0 25.0 50.0 75.0		50.0 175.0 200.0 225.0 250.0 ity (ACFM)	213.0 300.0 325.0	
	Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35				
	Note: Y-Axis Scale	, 10 to 35, + 5kW			

arty verification progr ticipants NOTES:

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.

Member:

b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.

c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,

manufacturer may state "not significant" or "0" on the test report. d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:



NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

	me Flow Rate ified conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{m^3 / min}$	<u>ft3 / min</u>	%	%	
Below 0.5	Below 15	+/- 7	+/- 8	
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10%
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	

ROT 031

5/11 R6 This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.