

**COMPRESSOR DATA SHEET**  
**Rotary Compressor: Variable Frequency Drive**

<b>MODEL DATA - FOR COMPRESSED AIR</b>			
1	Manufacturer: <b>Quincy Compressor</b>		
2	Model Number: <b>QGV-200</b>		Date: <b>August 2011</b>
	<input checked="" type="checkbox"/> Air-cooled <input type="checkbox"/> Water-cooled	Type: <b>Screw</b>	
	<input checked="" type="checkbox"/> Oil-injected <input type="checkbox"/> Oil-free	# of Stages: <b>1</b>	
3	Rated Operating Pressure	<b>125</b>	psig <sup>b</sup>
4	Drive Motor Nominal Rating	<b>200</b>	hp
5	Drive Motor Nominal Efficiency	<b>95.7</b>	percent
6	Fan Motor Nominal Rating (if applicable)	<b>2 X 5</b>	hp
7	Fan Motor Nominal Efficiency	<b>78.5</b>	percent
8*	Input Power (kW)	Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>
	179.3                      Max	846.3	<b>21.19</b>
	173.0	819.0	<b>21.12</b>
	167.0	790.0	<b>21.14</b>
	130.0	608.7	<b>21.36</b>
	91.0	386.5	<b>23.54</b>
49.7                      Min		173.2	<b>28.70</b>
9*	Total Package Input Power at Zero Flow <sup>c,d</sup>		kW
10		<div style="border: 1px solid black; padding: 10px;"> <p style="text-align: center; font-size: small;"> <b>Note: Graph is only a visual representation of the data in Section 8</b>                      Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35                      X-Axis Scale, 0 to 25% over maximum capacity                 </p> </div>	

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program: [www.cagi.org](http://www.cagi.org)

NOTES:

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$m^3/min$	$ft^3/min$	%	%	
Below 0.5	Below 15	+/- 7	+/- 8	+/- 10%
0.5 to 1.5	15 to 50	+/- 6	+/- 7	
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	

