## **COMPRESSOR DATA SHEET**

**Rotary Screw Compressor** 

MODEL DATA - FOR COMPRESSED AIR						
1	Manufacturer: Quincy Compressor					
	Model Number: QSI-440i		Date: May 2011			
2	X Air-cooled Water-cooled					
	X Oil-injected Oil-free	# of Stages:	Single			
	Rated Capacity at Full Load Operating					
3*	Pressure <sup>a, f</sup>	436	acfm <sup>a,f</sup>			
4	Full Load Operating Pressure b	125	psig b			
5	Maximum Full Flow Operating Pressure c	140	psig			
6	Drive Motor Nameplate Rating	100	hp			
7	Drive Motor Nameplate Nominal Efficiency	94.1	percent			
8	Fan Motor Nameplate Rating (if applicable)	3	hp			
9	Fan Motor Nameplate Nominal Efficiency	81.5	percent			
10*	Total Package Input Power at Zero Flow <sup>e</sup>	27.1	kW <sup>e</sup>			
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure <sup>d</sup>	90.4	$kW^{\mathrm{d}}$			
12*	Specific Package Input Power at Rated  Capacity and Full Load Operating Pressure	20.7	kW/100 cfm <sup>g</sup>			

NOTES:

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.

b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.

- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.

  d. Total package input power at other than reported operating points will vary with control strategy.

  e, f, g. Tolerance is specified in ISO 1217, Annex C, as shown in table below:



Member:

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy <sup>g</sup> Consumption	No Load / Zero Flow Power e
m <sup>3</sup> / min	ft3 / min	%	%	
Below 0.5	Below 15	+/- 7	+/- 8	
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10%
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	

ROT 030

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.

<sup>\*</sup> For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party program administrator