			otary Compressor: L DATA - FOR CO	A A A A A A A A A A A A A A A A A A A		
	1	Manufacturer: Quincy Compressor				
	Model Number: QSI 600		Date:	Aug-11		
	2	X Air-cooled	Water-cooled	Type:	Screw	
		X Oil-injected	Oil-free	# of Stages:	Single	
		Rated Capacity at Full Load Operating Pressure <sup>a, e</sup>		630	acfm <sup>a,e</sup>	
	3*					
	4	Full Load Operating Pressure b		100	psig <sup>b</sup>	
	5	Maximum Full Flow Operating Pressure <sup>c</sup>		115	psig <sup>c</sup>	
6		Drive MotorNominal Rating		125	hp	
	7 Drive Motor No		Efficiency	94.5	percent	
	8	Fan Motor Nominal Ra	ting (if applicable)	3	hp	
	9	9 Fan Motor Nominal Efficiency		87.5	percent	
	10*	Total Package Input Power at Zero Flow <sup>e</sup>		32	kW <sup>e</sup>	
	11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure <sup>d</sup>		106.7	$kW^d$	
	12*	Specific Package Input		16.0	kW/100 cfm <sup>e</sup>	
	*E 1	Capacity and Full Load Operating Pressure <sup>e</sup>		16.9	· · · · · · · · · · · · · · · · · · ·	·
Men co <sup>MPRE</sup> CA	Consult C NOTES: nber:	<ul> <li>AGI websitefor a list of partic</li> <li>a. Measured at the discha ISO 1217, Annex C; A</li> <li>b. The operating pressure for this data sheet.</li> <li>c. Maximum pressure atti maximum pressure atti</li> <li>d. Total package input po</li> </ul>		ification program: <u>v</u> ressor package in accordance ninute at inlet conditions. ) and Electrical Consumption e unload pressure setting for lo begins. May require addition rating points will vary with co	www.cagi.org with (Item 11) were measured pad/no load control or the al power.	
3 CAS INSTITU®		Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flo Power
		$\underline{m^3 / \min}$	<u>ft3 / min</u>	%	%	
		Below 0.5	Below 15	+/- 7	+/- 8	
		0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10%
		1.5 to 15 Above 15	50 to 500	+/- 5 +/- 4	+/- 6 +/- 5	
OT 030		AUUVE 13	Above 500	T/ = +	T/= J	L