## **COMPRESSOR DATA SHEET**

## Federal Uniform Test Method for Certain Air Compressors Not Applicable

**Rotary Compressor: Fixed Speed** 

MODEL DATA - FOR COMPRESSED AIR						
1	Manufacturer: Quincy Compressor					
Model Number: QOF-100		Date:	12/1/2021			
2	X Air-cooled Water-cooled	Type:	Screw			
	Oil-injected X Oil-free	# of Stages:	2			
	Rated Capacity at Full Load Operating Pressure					
3*	a, e	399.0	acfm <sup>a,e</sup>			
4	Full Load Operating Pressure b	125	psig b			
5	Maximum Full Flow Operating Pressure c	125	psig			
6	Drive Motor Nominal Rating	100	hp			
7	Drive Motor Nominal Efficiency	94.1	percent			
8	Fan Motor Nominal Rating (if applicable)	4.5	hp			
9	Fan Motor Nominal Efficiency	76	percent			
10*	Total Package Input Power at Zero Flow	25.7	kW <sup>e</sup>			
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure <sup>d</sup>	87.10	$kW^d$			
12*	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure <sup>e</sup>	21.84	kW/100 cfm <sup>e</sup>			

NOTES:

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the
  maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



Member

ROT 030.2

- 1	110 TE. The terms power and energy are synonymous for purposes of this document.							
	Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power			
	m³/min	ft <sup>3</sup> / min	%	%	%			
	Below 0.5	Below 17.6	+/- 7	+/- 8				
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%			
	1.5 to 15	53 to 529.7	+/- 5	+/- 6				
	Above 15	Above 529.7	+/- 4	+/- 5				

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

<sup>\*</sup>For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>